

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0410:0201 Page 1 of 2

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

**DESIGN:** Model RAI-LED smoke-automatic fire detector accessory. Designed specifically for use with listee's:

Photoelectric Smoke Detectors  
Model ALG-V (CSFM Listing No. 7272-0410:149),  
Model ALK-V (CSFM Listing No. 7272-0410:173),  
Model ACA-V (CSFM Listing No. 7272-0410:182),

Ionization Smoke Detector  
Model AIE-EA (CSFM Listing No. 7271-0410:148)

Heat Detector  
Model ATG-EA (CSFM Listing No. 7270-0410:147)

Bases  
Model HSB-NSA-6 (CSFM Listing No. 7300-0410:132)  
Model YBN-NSA-6 (CSFM Listing No. 7300-0410:132)  
Model ASB (CSFM Listing No. 7300-0410:161)  
Model SCI-B4 (CSFM Listing No. 7300-0410:186)  
Model SCI-B6 (CSFM Listing No. 7300-0410:186)

FACP  
Model FireNET (CSFM Listing No. 7165-0410:159)  
Model FireNET Plus (CSFM Listing No. 7165-0410:180)

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 7 mA

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a smoke-automatic fire detector accessory for use with the compatible detector

04-05-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*

heads, bases and Fire Alarm Control Panels [FACP] listed above to provide a remote visual indication of an alarm condition. Refer to listee's Installation Instruction Manual for details.

**NOTE:**

The notification appliance is supplemental and is NOT intended as the primary evacuation signal appliance.

04-05-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

*Listing Expires* **June 30, 2022**

Authorized By: **DAVID CASTILLO,, M.E., F.P.E.**  
*Fire Engineering Division*