

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0410:0206 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Models HCVR-3-R (115V), HCVR-3-R (230V), HCVR-3-C or HCVR-3-G (115 or 230V)
Releasing Panels.
Local, automatic, manual, waterflow and sprinkler supervisory service.

HCVR-3-ENC-BC f/b -R, -C or -G; Enclosure back box

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 115 Vac input.
230 Vac input.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model/catalog number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units suitable for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

XLF: 7165-2298:0502

10/06/2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division