

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0210 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Model ASBL low frequency 520 Hz addressable detector sounder base. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 17-41 Vdc

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a low frequency addressable detector base for use with listee's models ALG-V (CSFM No. 7272-0410:0149), ALK-V and ALK-V2 (CSFM No. 7272-0410:0173), ACA-V (CSFM No. 7272-0410:0182), AIE-EA (CSFM No. 7271-0410:0148), ATG-EA (CSFM No. 7270-0410:0147), ATJ-EA (CSFM No. 7270-0410:0203), ALN-V, ACC-V (CSFM No. 7272-0410:0204) and *Model ACD-V (CSFM Listing No. 7275-0410:0503) combination smoke/heat/CO detector heads. This unit can generate a low frequency alarm signal for sleeping areas in accordance with NFPA 72. Refer to listee's Installation Instructions Manual for details.

*Revision 05-23-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division