

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7275-0410:0503 Page 1 of 1

CATEGORY: 7275 -- COMBINATION SMOKE/CO DETECTOR-PHOTOELECTRIC TYPE

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Hochiki Model ACD-V, combination smoke/heat/CO detector head. Model ACD-V can be programmed by the FACP to be either a smoke detector, heat detector, CO detector, or a combination photoelectric/smoke, heat, and CO detector. Fixed temperature 135°F or a 15°F Rate of Rise detector, or CO detector head.

RATING: 24-41 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as a combination photoelectric smoke/heat/CO detector head for use with listee's separately listed compatible base and fire alarm control units. Also acceptable for duct application with air velocities from 0-4000 ft/min. Listed as heat type detector for use with listee's separately listed compatible base and fire alarm control units. Refer in Manufacturer's Installation Instruction Manual for details.

05-23-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division