

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7150-0410:0169

Page 1 of 1

**CATEGORY:** 7150 -- FIRE ALARM PULL BOXES

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

**DESIGN:** Models DCP-AMS, DCP-AMS-LP, DCP-AMS-KL, DCP-AMS-KL-LP, \*FF0-PULL-SH, \*FF0-PULL-SK, \*FF0-PULL-DH, and \*FF0-PULL-DK addressable fire alarm manual pull boxes. "LP", "DH" and "DK" suffixes are dual action boxes. "KL", "SK", and "DK" suffixes are key lock access boxes. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 33 Vdc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as fire alarm manual pull boxes for use with separately listed electrically and functionally compatible fire alarm control units.

These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition and California amendments except models with "LP", "DH", and "DK" suffixes.

\*Rev 01-12-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*