

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0410:0175 Page 1 of 1

CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Models FNV-MP and FNV-DP audio adjunct/voice evacuation systems. The FNV-MP is the master panel in the system while the FNV-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

FNV-PWR2A: Power Supply
FNV-MFP: Master Fire Phone Card
FNV-DCC : Data Communication Control Card
FNV-ASC : Audio System Control Card
FNV-SSC : Switch Scan Card
FNV-MMC : Microphone Master Control Card
FNV-IOI : Input/Output Card
FNV-SLC : Switch and LED Card
FNV-MFH : Master Fire Phone Handset Card
FNV-MBR :Motherboard Card
FNV-AMI : Audio Module Interface Card
FNV-FPI : Motherboard/Relay Card
FNV-25E, -50E or -100E : Audio Adjunct Systems*

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use with separately listed electrically compatible fire alarm control unit. Suitable for high rise applications when used in conjunction with separately listed electrically compatible high rise fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 6911-1446:0103

*Corrected 03-14-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO,, M.E., F.P.E.**
Fire Engineering Division