

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0410:0186 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

**DESIGN:** Models SCI-B4 and SCI-B6 Detector Isolator Bases. These models are to be used with listee's Models ACA-V, ALG-V, ALK-V, AIE-EA, and ATG-EA detector heads. The Model SCI-B6 is similar to Model SCI-B4 except for base size, 6 " base versus 4" base.

**RATING:** 17 - 41 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed for use as detector bases with Manufacturer's Models ACA-V, ALG-V, ALK-V, AIE-EA, ATG-EA, and \*ACD-V detector heads. Refer to manufacturer's installation instruction and manual for details.

\*Revision 05-23-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO,, M.E., F.P.E.**  
*Fire Engineering Division*