

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7120-0410:0157

Page 1 of 1

**CATEGORY:** 7120 -- ANNUNCIATORS

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

**DESIGN:** Model HRA-1000 remote multiplex annunciator panel. The main annunciator module provides indication for 32 zones. Each adder annunciator module provides indication for 48 additional zones. Unit includes main annunciator chassis HRAM-1032 and adder annunciator chassis HRAX-1048. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 20-29 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as annunciator panel for use with listee's separately listed compatible Model HPC-1000 fire alarm control unit (CSFM Listing No. 7165-0410:154).

**XLf:** 7120-1477:0107

\*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*