

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0410:0188 Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Models HES24-1575WR, HES24-1575WW, HES24-177WR, HES24-177WW, HES3-24WR, HES3-24WW, HES3-24PWR, HES3-24PWW strobe lights; Models HCS24CR, HCS24CW, HCS24PCR, HCS24PCW strobe lights (synchronization type) and Models HAVSM-R, HAVSM-W Sync Modules. Intended for indoor use and wall mount only. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: 15cd, 15cd & 75cd at 00 angle axis
30cd, 60cd, 75cd, 110cd, 177cd.
Model HCS24: Selectable 15cd, 30cd, 75cd, 95cd and 115cd
Model HES3-24: Selectable 15cd, 30cd, 60cd, 75cd and 110cd
Electrical: 21-30 VDC
HAVSM: 8-33 VDC/VFWR
Flash Rate: 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units.

XLF: 7125-0569:0123

08-03-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division