CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7165-0410:0154 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268

Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268

Email: tlujan@hochiki.com

DESIGN: HCP-1000 fire alarm control unit. Non-coded, automatic, manual, local, auxiliary, remote

station, waterflow and sprinkler supervisory service. System components:

HCP-1000 Control Unit HBB-1024, HBB-1072 Backbox 24-Zone Chassis HMCC-1024-6, -12 HMCC-1024-6S, -12S 24-Zone Chassis HECH-1048 **Expander Chassis** HDM-1008 8-Zone Detection Module HSGM-1004 4-Zone NAC Module HRM-1008 Relay Adder Module

HPR-100 Polarity Reversal and City Tie

HFA-1024TR Flush Trim Ring

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances,

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally

compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to

listee's Installation Manual for details.

This control unit meets the requirement of UL-864, 8th Edition Standard.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1477:0106

*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2021 Listing Expires June 30, 2022

Authorized By: **DAVID CASTILLO**, M.E., F.P.E.

Fire Engineering Division