

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0410:0147

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Models ATG - EA and FFO-HEAT electronic fixed temperature heat detector (analog) with Models YBN-NSA-4, HSB-NSA-6, FFO-4BASE or FFO-6BASE bases. Unit consists of resistors, capacitors, diodes, transistors, LED, thermistors, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 39.5 VDC
Temperature Range: 134°F - 149°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical/temperature rating and UL label.

APPROVAL: Listed as heat detector for use with separately listed compatible fire alarm control units.

Rev 08-13-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division