

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7320-0410:0194

Page 1 of 1

**CATEGORY:** 7320 -- SPEAKERS

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268  
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268  
Email: tlujan@hochiki.com

**DESIGN:** Models HSSPKCLPR, HSSPKCLPW speakers and Models HSSPK24CLPPR, HSSPK24CLPPW, HSSPK24CLPR and HSSPK24CLPW speaker strobes. Models HSSPKCLPR, HSSPKCLPW are intended for ceiling and wall mount. Other models are ceiling mounted only. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

Speaker	25 Vrms and 70.7 Vrms
Strobe	21-30 VDC
Flash Rate	60 flashes per minute
Candela	15, 30, 60, 75 & 15/75, 110

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. All models are intended for indoor use only and are mounted in a listed double-gang backbox.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Models HSSPK24CLPPR, HSSPK24CLPPW, HSSPK24CLPR and HSSPK24CLPW speaker strobes are suitable for the hearing impaired applications. For indoor use only. Refer to manufacturer's Installation Manual for details.

These devices do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation).

**XLF:** 7320-0569:0137

08-08-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*