

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7320-0410:0195

Page 1 of 1

CATEGORY: 7320 -- SPEAKERS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Tony Lujan (714) 670-3248 Fax (714) 522-2268
Email: tlujan@hochiki.com

DESIGN: Models HSSPK24WLPPR, HSSPK24WLPPW, HSSPK24WLPR, HSSPK24WLPW, HSSPK24-1575WLPPW, HSSPK24-1575WLPPR, HSSPK24-1575WLPR, and HSSPK24-1575WLPW speaker strobes. All models are intended for indoor use only and are wall mounted in a listed double-gang backbox. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

| | |
|------------|--|
| Speaker | 25 Vrms and 70.7 Vrms |
| Strobe | 24 VDC |
| Flash Rate | 60 flashes per minute |
| Candela | 15, 30, 60, 75 & 15/75, 110 for Model SSPK24WLP series 15/75 fixed candela for Model HSSPK24-1575WLP series |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Both models are suitable for the hearing impaired applications. For indoor use only. Refer to manufacturer's Installation Manual for details.

XLF: 7320-0569:0140

08-08-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division