



**FWSA.EX16201  
Fixed Condensed Aerosol Extinguishing System Units**

[Page Bottom](#)

**Fixed Condensed Aerosol Extinguishing System Units**

[See General Information for Fixed Condensed Aerosol Extinguishing System Units](#)

**HOCHIKI AMERICA CORP.**

EX16201

Suite 100  
7051 VILLAGE DR  
Buena Park, CA 90621 USA

Description	Part No.
<b>Aerosol-generating extinguishing system unit</b>	
condensed aerosol generator	FNX-20S
condensed aerosol generator	FNX-40S
condensed aerosol generator	FNX-80S
condensed aerosol generator	FNX-100S
condensed aerosol generator	FNX-200S
condensed aerosol generator	FNX-500S
condensed aerosol generator	FNX-1200
condensed aerosol generator	FNX-2000
condensed aerosol generator	FNX-3000
condensed aerosol generator	FNX-5700
Mounting bracket, 20 g	FNX-MB-20S
Mounting brackets, 40, 80 g	FNX-MB-4080S1/ FNX-MB-4080S2
Mounting bracket, 100, 200, 500 g	FNX-MB-125
Mounting bracket, 2000, 3000, 1200 g	FNX-MB-122030
Mounting bracket, 5700 g	FNX-MB-57
Design, Installation, Operation and Maintenance Manual, Version 1.02, dated September 2012 and revised February 2013	1700-11990

For Class A surface burning and Class B and C category hazards; not for use in hazardous (classified) locations. Temperature range -54 to +54°C.

[Last Updated](#) on 2013-07-29

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".