

TECHNICAL BULLETIN

The 9th Edition Network Annunciator cannot be networked directly to the Networkable FireNET Plus Panel. At least one networkable FireNET Panel is required in order to have the Network Annunciator function properly with the Networkable FireNET Plus Panel. The 9th edition FireNET Panel with NIC card, Network Annunciator and FireNET Plus Panel with NIC Card network schemes are as follows:

Minimum Network Requirements

- FireNET panel may be networked with:
 - (1) FireNET panel or
 - (1) FireNET Plus or
 - (1) FireNET Network Annunciator

- FireNET Plus may be networked with:
 - (1) FireNET Plus or
 - (1) FireNET panel or
 - (1) FireNET panel and FireNET Network Annunciator

- FireNET Network Annunciator may be networked with:
 - (1) FireNET panel or
 - (1) FireNET panel and (1) FireNET plus

If you have any questions regarding this matter please contact Technical Support.

Technical Support
1-800-845-6692
Technicalsupport@hochiki.com

Initial Release: 11/12/09
Rev. 1.00