

CERTIFICATE OF COMPLIANCE

Certificate Number 20120901-S2966
Report Reference S2966-20120831
Issue Date 2012-SEPTEMBER-01

Issued to: HOCHIKI AMERICA CORP
SUITE 100
7051 VILLAGE DR
BUENA PARK CA 90621

**This is to certify that
representative samples of**

HEAT-AUTOMATIC FIRE DETECTORS


Indoor Analog Addressable Combination 15°F Rate of Rise / 135-194°F Fixed Temperature Heat Detector Model: ATJ-EA.
For use with Listed Base Models HSB-NSA-6 or YBN-NSA-4

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: HEAT DETECTORS FOR FIRE PROTECTIVE SIGNALING SYSTEMS, ANSI/UL 521

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

